

**TABLE 1**  
**DRAFT SUMMARY OF SUSPECT PCB-CONTAINING EXTERIOR CAULKING**  
**JULIA STARK ELEMENTARY SCHOOL**  
**398 GLENBROOK ROAD**  
**STAMFORD, CONNECTICUT**

SOURCE	SUBSTRATE	SAMPLE LOCATION	PCB CONCENTRATION (PPM)							
			SOURCE	AROCLOR #	SUBSTRATE AT SOURCE MATERIAL	AROCLOR #	SUBSTRATE 6 INCHES FROM SOURCE	AROCLOR #	SUBSTRATE 12 INCHES FROM SOURCE	AROCLOR #
			SAMPLE #		SAMPLE #		SAMPLE #		SAMPLE #	
<b>1994 ADDITION</b>										
Blue Exterior Window Caulking	Exterior Brick	Exterior Room 172	ND <0.33	N/A						
			0104BS03D							
		Exterior Corridor Room 103/104	ND <0.82	N/A						
			0104BS03F							
		Exterior Media Center	ND <0.71	N/A						
			0228BS01							
Exterior Room 256	ND <0.33	N/A								
	0228BS12									
Exterior 201	1.50	1254								
	0228BS13 (Re-Analysis Sample Info)									
Blue Exterior Door Caulking	Exterior Brick	Exterior Media Center	ND <0.81	N/A						
			0104BS01A							
		Exterior Corridor at Room 101	ND <0.52	N/A						
			0228BS02							
White/Gray Exterior Expansion Joint Caulking	Exterior Brick	Exterior Media Center	ND <0.79	N/A						
			0104BS02A							
		Exterior Room 171	ND <0.76	N/A						
			0104BS02D							
		Exterior Rooms 170/172	3.10	1254						
			0104BS02E							
Exterior Room 104	ND <0.75	N/A								
	0104BS02G									

**TABLE 1**  
**DRAFT SUMMARY OF SUSPECT PCB-CONTAINING EXTERIOR CAULKING**  
**JULIA STARK ELEMENTARY SCHOOL**  
**398 GLENBROOK ROAD**  
**STAMFORD, CONNECTICUT**

SOURCE	SUBSTRATE	SAMPLE LOCATION	PCB CONCENTRATION (PPM)							
			SOURCE	AROCLOR #	SUBSTRATE AT SOURCE MATERIAL	AROCLOR #	SUBSTRATE 6 INCHES FROM SOURCE	AROCLOR #	SUBSTRATE 12 INCHES FROM SOURCE	AROCLOR #
			SAMPLE #		SAMPLE #		SAMPLE #		SAMPLE #	
<b>1969 ADDITION</b>										
Blue Exterior Window Caulking	Exterior Brick	Exterior Room 168	130	1254	0.99	1254	ND<0.75	N/A	ND<0.78	N/A
			0104BS10A		0301BS-AS-01		0301BS-AS-02		0301BS-AS-03	
		Exterior Room 169	620	1254						
			0228BS03							
		Exterior Room 252	1.2	1254						
			0228BS14							
Exterior Cafeteria	100	1254								
	0228BS04									
Residual Blue/Gray Window Caulking	Exterior Brick	Exterior Room 169	150,000	1254						
			0104BS10A							
	Exterior Room 168	320,000	1254	0.99	1254	ND<0.75	N/A	ND<0.78	N/A	
				Homogeneous Sample Location to As-01		Homogeneous Sample Location to As-02		Homogeneous Sample Location to As-03		
	Exterior Aluminum Window Frame	Exterior Room 169	0104BS10B		WIPE SAMPLE					
	Exterior Brick	Exterior Room 254	15,000	1254						
0228BS21										
Exterior Cafeteria	Exterior Cafeteria	7,700	1254							
		0228BS05								
Blue Exterior Door/Window Caulking	Exterior Brick	Exterior Stairwell at Room 171	2,600	1254	2.3	1254	0.98	1254	0.97	1254
					0301BS-AS-10		0301BS-AS-11		0301BS-AS-12	
	Exterior Aluminum Door/Window Frame	Exterior Stairwell at Room 172	0104BS11A		WIPE SAMPLE					

**TABLE 1**  
**DRAFT SUMMARY OF SUSPECT PCB-CONTAINING EXTERIOR CAULKING**  
**JULIA STARK ELEMENTARY SCHOOL**  
**398 GLENBROOK ROAD**  
**STAMFORD, CONNECTICUT**

SOURCE	SUBSTRATE	SAMPLE LOCATION	PCB CONCENTRATION (PPM)							
			SOURCE	AROCLOR #	SUBSTRATE AT SOURCE MATERIAL	AROCLOR #	SUBSTRATE 6 INCHES FROM SOURCE	AROCLOR #	SUBSTRATE 12 INCHES FROM SOURCE	AROCLOR #
			SAMPLE #		SAMPLE #		SAMPLE #		SAMPLE #	
White Exterior Door Caulking	Exterior Brick	Exterior North Side Custodain	690	1254						
			0104BS13A							
White Exterior Door Caulking - Type 2	Exterior Brick	Exterior Kitchen Double Door	2.2	1254						
			0104BS14A							
Gray Exterior Door Caulking	Exterior Brick	Exterior Cafeteria Double Door	42,000	1254	4.4*	1254	ND<0.81	N/A	ND<0.78	N/A
			0301BS-AS-06		0301BS-AS-07		0301BS-AS-08			
	Exterior Metal Door Frame	Exterior Cafeteria Double Door	0104BS15A		WIPE SAMPLE					
White/Gray Exterior Expansion Joint Caulking	Exterior Brick	Exterior Room 167	540,000	1254	6	1254	1.6	1254	ND<0.74	N/A
			0104BS02B		0301BS-AS-15		0301BS-AS-16		0301BS-AS-17	
		Exterior North Side Custodain	470,000	1254						
			0104BS02F							

**TABLE 1**  
**DRAFT SUMMARY OF SUSPECT PCB-CONTAINING EXTERIOR CAULKING**  
**JULIA STARK ELEMENTARY SCHOOL**  
**398 GLENBROOK ROAD**  
**STAMFORD, CONNECTICUT**

SOURCE	SUBSTRATE	SAMPLE LOCATION	PCB CONCENTRATION (PPM)							
			SOURCE	AROCLOR #	SUBSTRATE AT SOURCE MATERIAL	AROCLOR #	SUBSTRATE 6 INCHES FROM SOURCE	AROCLOR #	SUBSTRATE 12 INCHES FROM SOURCE	AROCLOR #
			SAMPLE #		SAMPLE #		SAMPLE #		SAMPLE #	
<b>1951 ADDITION</b>										
Blue Exterior Window Caulking	Exterior Brick	Exterior Computer Lab	ND <0.79	N/A						
			0104BS03A							
	Exterior Stone Sill	Exterior Computer Lab	ND <0.81	N/A						
			0104BS06A							
	Exterior Stone Sill	Exterior Teachers Lounge	ND <0.85	N/A						
			0228BS20							
	Exterior Brick	Exterior Auditorium Lobby Toilet Room	<b>2.4</b>	1254						
			ADJACENT SAMPLE							
	Exterior Aluminum Window Frame	Exterior Auditorium Lobby Toilet Room	0228BS10							
			WIPE SAMPLE							
	Exterior Stone Sill	Exterior Auditorium Lobby Toilet Room	ND <0.41	N/A						
			0228BS11							
	Exterior Brick	Exterior Room 105	<b>1.1</b>	1254						
			0228BS08							
	Exterior Stone Sill	Exterior Room 105	ND <0.76	N/A						
			0228BS09							
	Exterior Brick	Exterior Room 245	0.94	1254						
			0228BS18							
Exterior Stone Sill	Exterior Room 241	ND <0.88	N/A							
		0228BS19								
Exterior Stone Sill	Exterior Room 237	ND <0.59	N/A							
		0228BS17								

**TABLE 1**  
**DRAFT SUMMARY OF SUSPECT PCB-CONTAINING EXTERIOR CAULKING**  
**JULIA STARK ELEMENTARY SCHOOL**  
**398 GLENBROOK ROAD**  
**STAMFORD, CONNECTICUT**

SOURCE	SUBSTRATE	SAMPLE LOCATION	PCB CONCENTRATION (PPM)									
			SOURCE	AROCLOR #	SUBSTRATE AT SOURCE MATERIAL	AROCLOR #	SUBSTRATE 6 INCHES FROM SOURCE	AROCLOR #	SUBSTRATE 12 INCHES FROM SOURCE	AROCLOR #		
			SAMPLE #		SAMPLE #		SAMPLE #		SAMPLE #			
Blue Exterior Door Caulking	Exterior Brick	Exterior Stairwell at Room 157	ND <0.80	N/A								
			0104BS01B									
	Exterior Brick	Exterior Room 105	ND<0.47	N/A								
			0228BS06									
	Exterior Brick	Exterior Room 104	ND<0.52	N/A								
			0228BS07									
White Door Caulking - Type 3	Exterior Brick	Exterior Teachers Lounge	ND <0.39	N/A								
			0104BS17A									
Blue Exterior Door/Window Storefront Caulking	Exterior Brick	Exterior Auditorium Lobby	<b>1.50</b>	1254	ND<0.33	N/A						
			0104BS01C		0301BS-AS-05							
	Exterior Glazed Block	Exterior Auditorium Lobby	<b>1.10</b>	1254	ND<0.72	N/A						
					0301BS-AS-04							
	Exterior Aluminum Window Frame	Exterior Auditorium Lobby	<b>0104BS12A</b>		WIPE SAMPLE							
	Exterior Stone	Exterior Main Entrance	<b>1.30</b>	1254	ND<0.33	N/A						
					0301BS-AS-14							
	Exterior Aluminum Window Frame	Exterior Main Entrance	<b>0104BS20A</b>		WIPE SAMPLE							
White Exterior Vent Caulking	Exterior Brick	Exterior Teachers Lounge	ND <0.79	N/A								
			0104BS18A									

**TABLE 1**  
**DRAFT SUMMARY OF SUSPECT PCB-CONTAINING EXTERIOR CAULKING**  
**JULIA STARK ELEMENTARY SCHOOL**  
**398 GLENBROOK ROAD**  
**STAMFORD, CONNECTICUT**

SOURCE	SUBSTRATE	SAMPLE LOCATION	PCB CONCENTRATION (PPM)							
			SOURCE	AROCLOR #	SUBSTRATE AT SOURCE MATERIAL	AROCLOR #	SUBSTRATE 6 INCHES FROM SOURCE	AROCLOR #	SUBSTRATE 12 INCHES FROM SOURCE	AROCLOR #
			SAMPLE #		SAMPLE #		SAMPLE #		SAMPLE #	
White Exterior Vent Caulking - Type 2	Exterior Brick	Exterior Nurses Office	7.60	1254	ND<0.73	N/A				
					0301BS-AS-09					
	Exterior Aluminum Vent Frame	Exterior Nurses Office	0104BS19B		WIPE SAMPLE					
White Exterior Brittle Expansion Joint Caulking	Exterior Brick	Exterior NE Corner Cafeteria	ND <0.77	N/A						
			0104BS16A							
	Exterior Brick	Exterior Room 105								
	Exterior Brick	Exterior First Floor Toilet Room at Assitant Principals Office								

**TABLE 1**  
**DRAFT SUMMARY OF SUSPECT PCB-CONTAINING EXTERIOR CAULKING**  
**JULIA STARK ELEMENTARY SCHOOL**  
**398 GLENBROOK ROAD**  
**STAMFORD, CONNECTICUT**

SOURCE	SUBSTRATE	SAMPLE LOCATION	PCB CONCENTRATION (PPM)							
			SOURCE	AROCLOR #	SUBSTRATE AT SOURCE MATERIAL	AROCLOR #	SUBSTRATE 6 INCHES FROM SOURCE	AROCLOR #	SUBSTRATE 12 INCHES FROM SOURCE	AROCLOR #
			SAMPLE #		SAMPLE #		SAMPLE #		SAMPLE #	
<b>ORIGINAL BUILDING</b>										
Blue Exterior Window Caulking	Exterior Stone Sill/Brick Jambs	Exterior Room 105	ND <0.78	N/A						
			0104BS06B							
	Exterior Stone Sill/Brick Jambs	Exterior Room 104	Source Sample							
	Exterior Stone Sill/Brick Jambs	Exterior First Floor Toilet Room at Assitant Principals Office	Source Sample							
	Exterior Stone Insert	Exterior Room 116	<b>25</b>	1254	<b>8.7</b>	1254				
			0301BSAS13		Adjacent Sample of Brick					
	Exterior Aluminum Window Frame	Exterior Room 116	0104BS21A		WIPE SAMPLE					
	Exterior Stone Insert	Exterior Room 119	<b>1.40</b>	1254						
			0104BS21B							
	Exterior Stone Insert	Exterior Room 220	ND<0.58	N/A						
			0228BS16							
	Exterior Stone Insert	Exterior Room 223	ND<0.34	N/A						
		0228BS15								
Residual White Door Caulking	Exterior Brick	Exterior Door at Room 104/103	ND <0.74	N/A						
			0104BS22A							
	Exterior Brick	Exterior Door at Stairwell at First Floor Toielt Room	Source Sample							

\* Duplicate 0301BS-AS-08-D (0.86 PPM)