

## Stark

- [Summer As Built Update From Bismark](#)
- Media center re-caulking
  - Project completion date will be known shortly
- Installed temporary flashing on all windows. Further temporary work will be performed this summer to prevent water intrusion
  - Exterior caulking work began on 7/24
- More extensive long term exterior brick envelope project being designed for next summer.
  - Involves replacing windows and disposing of PCBs.
  - A/E firm still determining extent of repairs needed.
    - Building envelope study has begun
- Wall paper removal project
  - 80% completed for this summer
  - Should be completed this summer
- Waterproofing of planters are being worked on currently
- 1<sup>st</sup> floor Girls bathroom pipe break
  - Project commenced a year ago, SAMG discovered there was no contract with Portanova. Bismark to take over project and present timeline and budget.
- Infrared Roof Scan
  - [Roof Model](#)
  - [Roof Report](#)
- Playgrounds
  - Playground Medic performed an assessment of playgrounds throughout the City and crafted reports on issues found. SAMG to assess.

If you have any additional questions, please email  
**[SAMG@stamfordct.gov](mailto:SAMG@stamfordct.gov)**