

PHASE CONTRAST MICROSCOPY AREA AIR SAMPLING DATA SHEET

Tighe&Bond

Project Name: Stamford - Mold Task Force
 Project Location: KT Murphy E.S.
 Work Area Designation: Rooms 4, 6, 8, 10, 12 & Hallway
 Microscope #: 3

Project Number: 28-2087-033
 Sampling Date: 2/15/19 + 2/16/19
 Project Monitor Name: Randy Taylor
 Project Monitor License #: 743

Sample #	Sample Location	Project Activity	Sample Time (minutes)			Flow Rate (Liters/Minute)		Average Flow Rate (Liters/Min)	Total Volume (Liters)	Fiber Count (Fib/Field)	Concentration (Fibers/CC)
			On	Off	Min	Pre	Post				
021519RT-01	Field Blank	Background	-	-	-	-	-	-	-	0/100	<0.002
-02	Scaled Blank	I	-	-	-	-	-	-	-	0/100	<0.002
-03	Decon	Background	0834	1416	342	7.0	7.0	7.0	2394	6/100	<0.002
-04	Cafe Entry	Background	0836	1418	342	7.0	7.0	7.0	2394	2/100	<0.002
-05C	Hall by Room 4	Clearance	1157	1335	98	14.9	14.9	14.9	1460.2	11/100	0.0036
-06C	I	I	1158	1335	97	14.9	14.9	14.9	1445.3	7/100	0.0023
-07C	I	I	1159	1335	96	14.9	14.9	14.9	1430.4	9/100	0.003
-08C	I	I	1200	1335	95	14.9	14.9	14.9	1415.5	9/100	0.0031
-09C	I	I	1201	1335	94	14.9	14.9	14.9	1400.6	10/100	0.0035
-10C	Room 4	I	1211	1350	99	14.9	14.9	14.9	1475.1	8/100	0.0026

Chain of Custody and Sample Receiving Log

		Date:	Time:	AAR#
Samples Analyzed By:	<u>Randy Taylor</u>	<u>2/16/19</u>		<u>9450</u>
Sample Collected By:	<u>Randy Taylor</u>	<u>2/15/19 + 2/16/19</u>		
Samples Relinquished By:				
Samples Received By:				
Results Reviewed By:				

PHASE CONTRAST MICROSCOPY AREA AIR SAMPLING DATA SHEET

Tighe & Bond

Project Name: Stamford - Mold Task Force
 Project Location: KT Murphy E.S. -
 Work Area Designation: Rooms 4, 6, 8, 10, 12, and Hallway
 Microscope #: 3

Project Number: 28-2087-033
 Sampling Date: 2/15/19 + 2/16/19
 Project Monitor Name: Randy Taylor
 Project Monitor License #: 943

Sample #	Sample Location	Project Activity	Sample Time (minutes)			Flow Rate (Liters/Minute)		Average Flow Rate (Liters/Min)	Total Volume (Liters)	Fiber Count (Fib/Field)	Concentration (Fibers/CC)	
			On	Off	Min	Pre	Post					
021519RT-01C	Room 4	Clearance	1212	1350	98	14.9	14.9	14.9	1460.2	6/100	0.002	
-12C			1213	1350	97	14.9	14.9	14.9	1445.3	5/100	<0.002	
-13C			1214	1350	96	14.9	14.9	14.9	1430.4	9/100	0.003	
-14C			1215	1350	95	14.9	14.9	14.9	1415.5	7/100	0.0024	
-15C			Hall by Room 12	0617	0752	95	14.9	14.9	14.9	1415.5	6/100	0.002
-16C			0618	0753	95	14.9	14.9	14.9	1415.5	4/100	<0.002	
-17C			0619	0754	95	14.9	14.9	14.9	1415.5	8/100	0.0027	
-18C			0620	0755	95	14.9	14.9	14.9	1415.5	7/100	0.0024	
-19C			0621	0756	95	14.9	14.9	14.9	1415.5	8/100	0.0027	
-19C			Duplicate	DUP	-	-	-	-	-	-	10/100	0.0034

Chain of Custody and Sample Receiving Log

		Date:	Time:	AAR#
Samples Analyzed By:	<u>Randy Taylor</u>	<u>2/16/19</u>		<u>9456</u>
Sample Collected By:	<u>Randy Taylor</u>	<u>2/15/19 + 2/16/19</u>		
Samples Relinquished By:				
Samples Received By:				
Results Reviewed By:				

PHASE CONTRAST MICROSCOPY AREA AIR SAMPLING DATA SHEET

Tighe & Bond

Project Name: Stamford - Mold Task Force
 Project Location: KT Murphy E.S.
 Work Area Designation: Rooms 4, 6, 8, 10, 12, + Hallway
 Microscope #: 3

Project Number: 28-2087-033
 Sampling Date: 2/15/19 + 2/16/19
 Project Monitor Name: Randy Taylor
 Project Monitor License #: 743

Sample #	Sample Location	Project Activity	Sample Time (minutes)			Flow Rate (Liters/Minute)		Average Flow Rate (Liters/Min)	Total Volume (Liters)	Fiber Count (Fib/Field)	Concentration (Fibers/CC)		
			On	Off	Min	Pre	Post						
021519RT-020C	Room 6	Clearance	0631	0808	97	14.9	14.9	14.9	1445.3	2/100	<0.002		
-21C			0632	0809	97	14.9	14.9	14.9	1445.3	1/100	<0.002		
-22C			0633	0810	97	14.9	14.9	14.9	1445.3	1/100	<0.002		
-23C			0634	0811	97	14.9	14.9	14.9	1445.3	2/100	<0.002		
-24C			0635	0812	97	14.9	14.9	14.9	1445.3	0/100	<0.002		
-25C			Room 10		0800	0933	93	14.9	14.9	14.9	1385.7	1/100	<0.002
-26C					0801	0934	93	14.9	14.9	14.9	1385.7	2/100	<0.002
-27C					0802	0935	93	14.9	14.9	14.9	1385.7	1/100	<0.002
-28C					0803	0936	93	14.9	14.9	14.9	1385.7	3/100	<0.002
-29C					0804	0937	93	14.9	14.9	14.9	1385.7	1/100	<0.002

Chain of Custody and Sample Receiving Log

Samples Analyzed By:	<u>Randy Taylor</u>	Date:	<u>2/16/19</u>	Time:		AAR#	<u>9450</u>
Sample Collected By:	<u>Randy Taylor</u>	Date:	<u>2/15/19 + 2/16/19</u>	Time:			
Samples Relinquished By:		Date:		Time:			
Samples Received By:		Date:		Time:			
Results Reviewed By:		Date:		Time:			

PHASE CONTRAST MICROSCOPY AREA AIR SAMPLING DATA SHEET

Tighe&Bond

Project Name: Stamford - Mold Task Force
 Project Location: KT Murphy E.S.
 Work Area Designation: Rooms 4, 6, 8, 10, 12, + Hallway
 Microscope #: 3

Project Number: 28-2087-033
 Sampling Date: 2/15/19 + 2/16/19
 Project Monitor Name: Randy Taylor
 Project Monitor License #: 743

Sample #	Sample Location	Project Activity	Sample Time (minutes)			Flow Rate (Liters/Minute)		Average Flow Rate (Liters/Min)	Total Volume (Liters)	Fiber Count (Fib/Field)	Concentration (Fibers/CC)		
			On	Off	Min	Pre	Post						
021519RT-30C	Room 8	Clearance	0815	0958	103	14.9	14.9	14.9	1534.7	1/100	<0.002		
-31C			0816	0959	103	14.9	14.9	14.9	1534.7	0/100	<0.002		
-32C			0817	1000	103	14.9	14.9	14.9	1534.7	1/100	<0.002		
-33C			0818	1001	103	14.9	14.9	14.9	1534.7	2/100	<0.002		
-34C			0819	1002	103	14.9	14.9	14.9	1534.7	0/100	<0.002		
-35C			Room 12 - Window	0948	1144	116	14.9	14.9	14.9	1728.4	3/100	<0.002	
-36C					0949	1145	116	14.9	14.9	14.9	1728.4	2/100	<0.002
-37C					0950	1146	116	14.9	14.9	14.9	1728.4	1/100	<0.002
-38C					0951	1147	116	14.9	14.9	14.9	1728.4	2/100	<0.002
-39C	0952	1148			116	14.9	14.9	14.9	1728.4	1/100	<0.002		

Chain of Custody and Sample Receiving Log

Samples Analyzed By:	<u>Randy Taylor</u>	Date:	<u>2/16/19</u>	Time:		AAR#	<u>9450</u>
Sample Collected By:	<u>Randy Taylor</u>	Date:	<u>2/15/19 + 2/16/19</u>	Time:			
Samples Relinquished By:		Date:		Time:			
Samples Received By:		Date:		Time:			
Results Reviewed By:		Date:		Time:			

PHASE CONTRAST MICROSCOPY AREA AIR SAMPLING DATA SHEET

Tighe&Bond

Project Name: Stamford - Mold Task Force
 Project Location: KT Murphy E.S.
 Work Area Designation: Room 4, 6, 8, 10, 12 + Hallway
 Microscope #: 3

Project Number: 28-2087-033
 Sampling Date: 2/15/19 + 2/16/19
 Project Monitor Name: Randy Taylor
 Project Monitor License #: 743

Sample #	Sample Location	Project Activity	Sample Time (minutes)			Flow Rate (Liters/Minute)		Average Flow Rate (Liters/Min)	Total Volume (Liters)	Fiber Count (Fib/Field)	Concentration (Fibers/CC)
			On	Off	Min	Pre	Post				
021519RT-4cc	Room 12-Center	Clearance	1006	1150	104	14.9	14.9	14.9	1549.6	2/100	<0.002
-41C			1007	1151	104	14.9	14.9	14.9	1549.6	1/100	<0.002
-42C			1008	1152	104	14.9	14.9	14.9	1549.6	1/100	<0.002
-43C			1009	1153	104	14.9	14.9	14.9	1549.6	3/100	<0.002
-44C			1010	1154	104	14.9	14.9	14.9	1549.6	2/100	<0.002

Chain of Custody and Sample Receiving Log

Samples Analyzed By:	<u>Randy Taylor</u>	Date:	<u>02-16-19</u>	Time:		AAR#	<u>9450</u>
Sample Collected By:	<u>Randy Taylor</u>	Date:	<u>02/15/19 + 2/16/19</u>	Time:			
Samples Relinquished By:		Date:		Time:			
Samples Received By:		Date:		Time:			
Results Reviewed By:		Date:		Time:			