

KT Murphy

- [Summer Work](#) plans released by Tighe and Bond
- Corridor by rooms 1-12- Full asbestos abatement project
 - Hallway Ceilings and Skylights- this summer
 - Classrooms – Summer 2020
- Room 36
 - Removal of impacted carpeting and ceiling tiles this summer.
- Custodian's Closet and Gym Offices
 - Removal of mold growth and water impacted drywall as well as select sections of ceiling and plaster wall. Asbestos materials will be removed using proper containment procedures.
 - [Photolog](#)
 - [Test Results](#)
- Skylights
 - Will be a summer project,
 - Wood framing around skylights is impacted by mold and will need to be replaced.
 - Should have details this week
- Infra-red Roof Analyzers
 - [Roof Model](#)
 - [Roof Report](#)
- Sump pump and Sewer Ejector pump
 - Analyzing two current options for sump pump design to determine both the most effective and practical replacement for the current pump. S & P to hire [GZA](#) to better understand variables to determine which option is best.

1. New sump pump in boiler room that will discharge waste to catch basin
2. Bigger hole and pump in current location
 - Ejector pump- looking to create an entrance not in classroom to avoid leaks into class.
- Hatch underneath stage
 - Silver pet to investigate hatch underneath auditorium stage.

If you have any additional questions, please email

Moldtaskforce@stamfordct.gov