

## KT Murphy

- [Summer Work](#) plans released by Tighe and Bond
- Corridor by rooms 1-12- Full asbestos abatement project
  - Hallway Ceilings and Skylights- this summer
  - Classrooms – Summer 2020
- Room 36
  - Removal of impacted carpeting and ceiling tiles this summer.
- Custodian's Closet and Gym Offices
  - Removal of mold growth and water impacted drywall as well as select sections of ceiling and plaster wall. Asbestos materials will be removed using proper containment procedures.
    - [Photolog](#)
    - [Test Results](#)
- Skylights - Will be a summer project, glass will need to be ordered soon. Wood framing around skylights is impacted by mold and will need to be replaced in summer as well.
- Waiting for Roof scan report to determine fix for leaks in book room.
- Sump pump and Sewer Ejector pump
  - Analyzing two current options for sump pump design to determine both the most effective and practical replacement for the current pump.
    1. New sump pump in boiler room that will discharge waste to catch basin
    2. Bigger hole and pump in current location

If you have any additional questions, please email  
[Moldtaskforce@stamfordct.gov](mailto:Moldtaskforce@stamfordct.gov)