

Newfield

- Duct Cleaning in media center and auditorium will be completed this summer
- Gym/Cafeteria Floor Replacement will take place this summer
 - Project will cost approximately \$150,000
 - Gym pads will be replaced.
 - Bismark currently painting the gym.
 - Floor replacement scheduled to begin July 31st.
 - Further roof drain issue being investigated
 - 4 inch drainage pipes lead into 3 inch pipes, creating possible volume concerns.
 - Fittings to be replaced by Bismark.
- Media center sheetrock and re-caulking
 - Project to bid out combined with work at Newfield, Hart, and Stark
- Kiln Room
 - Kiln rooms district wide being evaluated by Silver Petrucelli
 - Kilns need to be manufacturer's standards according to City code.
- 4 fans and 2 dehumidifiers have been rented and installed by Viking Construction to assist in improving air circulation and moisture levels over the summer.
- Minimal Asbestos abatement
 - Specs to be drafted by Tighe & Bond
- Full roof drains to be cleared and repaired this summer
 - City to supply roofing, plumbing and site plans for Bismark.
- Tree work to be performed this summer
- Test Results

- [Rooms 202, 207 and Teacher's Lounge](#)
- Infrared Roof Scans
 - [Roof Model](#)
 - [Roof Report](#)

If you have any additional questions, please email
SAMG@stamfordct.gov