

Newfield

- Duct cleaning in media center and auditorium will be completed this week.
- Gym/Cafeteria Floor Replacement
 - Floor replacement completed
 - Waxing and Striping to be completed this week.
 - Gym painted by McKenzie
 - Gym pads will arrive on 8/21.
 - Further roof drain issue being investigated
 - 4 inch drainage pipes lead into 3 inch pipes, creating possible volume concerns.
 - Roof drain issue fixed by Bismark
- Media center sheetrock and re-caulking
 - Re-caulking windows and gaskets this week. Project will be completed before school starts
 - Work to be performed by Commercial Glass
- Kiln Room
 - Kiln rooms district wide being evaluated by Silver Petrucelli
 - Kilns need to be manufacturer's standards according to City code.
- 4 fans and 2 dehumidifiers have been rented and installed by Viking Construction to assist in improving air circulation and moisture levels over the summer.
- Minimal asbestos abatement
 - Completed
- Full roof drains to be cleared and repaired this summer
 - Sections of roof drains varying in size have been replaced in the following locations:

- Gym
- Room 317
- 209A
- 305
- Tree work to be performed this summer
- Playgrounds
 - Playground Medic performed an assessment of playgrounds throughout the City and crafted reports on issues found. SAMG to assess.
- Test Results
 - [Rooms 202, 207 and Teacher's Lounge](#)
- Infrared Roof Scans
 - [Roof Model](#)
 - [Roof Report](#)

If you have any additional questions, please email
SAMG@stamfordct.gov