

Northeast

- April Break
 - Rooms 226, 227, 232, Teachers' lounge
 - Removed drywall and asbestos taping compound. AAIS cleaned and disinfected area.
 - Removed millwork cabinets to evaluated area for mold.
 - Teachers were moved back into classrooms today, teachers room should be ready by Wednesday
 - Art Room/ Book Storage-
 - Removed and replaced drywall, no asbestos.
 - Clean and disinfected area.
 - [Custodian closet and Nurses room](#)
 - Remove drywall and asbestos taping from floor to four feet in custodian closet and from floor to ceiling in nurse's room. Work was performed in negative pressure. Both rooms are now currently open

- Water fountain assessment to be performed this summer
 - Water fountains to be upgraded to units similar to Davenport
- HVAC
 - Tucker mechanical to provide HVAC to three additional rooms to prevent mold growth in future
 - Teachers Room
 - Custodian Closet
 - Book Storage
 - Exhaust Fans- Replace all 18 exhaust fans
- Media Center Roof - Gottfried
 - This summer- waiting for a number from Gottfried