



EMSL Analytical, Inc.

307 West 38th Street New York, NY 10018

Tel/Fax: (212) 290-0051 / (212) 290-0058

<http://www.EMSL.com> / manhattanlab@emsl.com

EMSL Order: 031908143
Customer ID: TIGH62
Customer PO:
Project ID:

Attention: Randy Taylor Tighe & Bond 213 Court Street Suite 1100 Middletown, CT 06457 Project: 28-2087-033/ STAMFORD - MOLD TASK FORCE - NORTHEAST/ AAIS/ SHEETROCK/ TAPING COMPOUND, MUDDER PIPE INSULATION	Phone: (860) 704-4760 Fax: (860) 704-4775 Received Date: 04/13/2019 20:25 PM Analysis Date: 04/14/2019 Collected Date: 04/13/2019
--	--

Test Report: Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Appendix A to Subpart E

Sample	Location	Volume (Liters)	Area Analyzed (mm ²)	Non Asb	Asbestos Type(s)	#Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration	
						≥0.5μ < 5μ	≥5μ		(S/mm ²)	(S/cc)
041319RT-01TC 031908143-0001	ROOM 227	1272.00	0.0640	0	None Detected	0	0	0.0047	<16.00	<0.0047
041319RT-02TC 031908143-0002	ROOM 227	1272.00	0.0640	0	None Detected	0	0	0.0047	<16.00	<0.0047
041319RT-03TC 031908143-0003	ROOM 232	1272.00	0.0640	0	None Detected	0	0	0.0047	<16.00	<0.0047
041319RT-04TC 031908143-0004	ROOM 226	1272.00	0.0640	0	None Detected	0	0	0.0047	<16.00	<0.0047
041319RT-05TC 031908143-0005	ROOM 226	1272.00	0.0640	0	None Detected	0	0	0.0047	<16.00	<0.0047

Analyst(s)

Muhsin Parson (5)

James Hall, Laboratory Manager
or other approved signatory

EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. This report must not be used to claim product certification, approval, or endorsement by NVLAP, NIST, or any agency of the federal government. Results reported in both structures/cm³ and structures/mm² are dependent on the volume of air sampled and measured by non-laboratory personnel are not the responsibility of EMSL and are not covered by the laboratory's NVLAP accreditation. Samples received in good condition unless otherwise noted. Estimated accuracy, precision and uncertainty data available upon request.

Samples analyzed by EMSL Analytical, Inc. New York, NY NVLAP Lab Code 101048-9, AIHA-LAP, LLC--IHLAP Accredited #102581, NYS ELAP 11506, NJ NY022, CT PH-0170, MA AA000170

Initial report from: 04/14/2019 04:01 AM

031908143

Tighe & Bond

TRANSMISSION ELECTRON MICROSCOPY AREA AIR SAMPLING DATA SHEET

Project Number: 28-2087-033 Date: 4/13/19
 Project Name: Stamford - Mold Task Force - Northeast
 Contractor: AAIS License Number: 017
 Project Monitor: Randy Taylor Project Monitor License Number: 743
 Scope of Work: Sheetrock/Taping Compound, Mudded Pipe Insulation

Sample ID Number	Sample Location	I/O	Sample Time		Sample Duration (Min.)	Flow Rate			Total Volume (Liters)
			On	Off		Pre	Post	Avg.	
041319RT-01TC	Room 227	1	1636	1915	159	8.0	8.0	8.0	1272
-02TC	Room 227	1	1637	1916	159	8.0	8.0	8.0	1272
-03TC	Room 232	1	1638	1917	159	8.0	8.0	8.0	1272
-04TC	Room 226	1	1639	1918	159	8.0	8.0	8.0	1272
-05TC	Room 226	1	1640	1919	159	8.0	8.0	8.0	1272
-06TC	OCB - Reson	0	1642	1921	159	8.0	8.0	8.0	1272
-07TC		0	1643	1922	159	8.0	8.0	8.0	1272
-08TC		0	1644	1923	159	8.0	8.0	8.0	1272
-09TC		0	1645	1924	159	8.0	8.0	8.0	1272
-10TC		0	1646	1925	159	8.0	8.0	8.0	1272
-11TC	Field Blank (In)	1	---	---	---	---	---	---	---
-12TC	Field Blank (Out)	0	---	---	---	---	---	---	---
-13TC	Sealed Control Blank	---	---	---	---	---	---	---	---

RECEIVED
2019 APR 13 PM 8:25

Samples Collected By: Randy Taylor Date: 4/13/19 Time: /
 Samples Rec'd/Sent By: Randy Taylor Date: 4/13/19 Time: /
 Shipped to: EMSL (State) UPS Overnight UPS Ground Other
 Shipment Method: FedEx UPS Overnight UPS Ground Other
 Analysis Method: TEM AHERA Turnaround Time: 12 hours Special Instructions:
 Email to: [Signature]

213 Court Street • Middletown, CT 06457 • Tel 860.704.4760 • Fax 860.704.4775

Rec'd: Duo da Aona 4/13/19 8:25 PM
 [Handwritten notes and signatures]