



Legend	
-----	EXPANSION JOINT
T2	THERMOGRAM
NIC	NOT IN CONTRACT
■	SUSPECTED WET INSULATION

✦ DRAIN

Areas: Total of All Roofs (in approximate square feet)	
Square Footage of Roof Inspected:	43,840
Square Footage of Suspected Wet Area:	55
Percentage of Suspected Wet Area:	<1%

**INFRA-RED ROOF MOISTURE ANALYSIS**



**IR ANALYZERS**  
**Vector Mapping**  
 INFRARED • ELD FUSION • NUCLEAR  
 P: (800) 879-1964 • F: 866-506-3522 • email: info@iranalyzers.com  
 NATIONWIDE SERVICE

VIKING CONSTRUCTION  
 BRIDGEPORT, CT  
 ROGERS INTER. SCHOOL  
 STAMFORD, CT

SCALE:	3/64"=1'-0"
DATE:	06-03-19
PAGE:	1 OF 1
DRAWN BY:	DMR
JOB#:	19231X11