

Areas: Total of All Roofs	(in approximate square feet)	108,088
Square Footage of Roof Inspected:		17,189
Square Footage of Suspected Wet Area:		15.9%
Percentage of Suspected Wet Area:		15.9%

Legend	
	THERMOGRAM
	SUSPECTED WET INSULATION
	SKYLIGHT
	DRAIN



INFRA-RED ROOF MOISTURE ANALYSIS

IR ANALYZERS
Vectr Mapping
 INFRARED • ELD FUSION • NUCLEAR
 P. (800) 879-1964 • F. 866-506-3522 • email: info@iranalyzers.com
 NATIONWIDE SERVICE

VIKING CONSTRUCTION
 BRIDGEPORT, CT
 ROXBURY ELEMENTARY
 STAMFORD, CT

SCALE: 3/64"=1'-0"
DATE: 04-17-19
PAGE: 1 OF 1
DRAWN BY: DMR
JOB#: 19231X01

