


Legend	
	THERMOGRAM
	SUSPECTED WET INSULATION
	DRAIN

Areas: Total of All Roofs (in approximate square feet)		
Square Footage of Roof Inspected:	57,297	
Square Footage of Suspected Wet Area:	1,956	
Percentage of Suspected Wet Area:	3.4%	



INFRA-RED ROOF MOISTURE ANALYSIS



IR ANALYZERS
Vectr Mapping
 INFRARED • ELD FUSION • NUCLEAR
 P: (800) 879-1964 • F: 866-506-3522 • email: info@iranalyzers.com
 NATIONWIDE SERVICE

VIKING CONSTRUCTION
 BRIDGEPORT, CT
 SPRINGDALE SCHOOL
 STAMFORD, CT

SCALE:	3/64"=1'-0"
DATE:	05-06-19
PAGE:	1 OF 1
DRAWN BY:	DMR
JOB#:	19231X05