

PHASE CONTRAST MICROSCOPY AREA AIR SAMPLING DATA SHEET

Tighe & Bond

Project Number: 28-2087-033 Date: 11-15-19


Project Name: Mold Task Force License Number:


Contractor: AAIS Project Monitor License Number:

Project Monitor: Randy Taylor

Scope of Work: Background Roof H Replacement

| Sample ID Number | Sample Location | Project Activity | Sample Time | | Sample Duration (Min.) | Flow Rate | | | Volume (Liters) | Fiber Count (Fib/Field) | Concentration (Fibers/CC) |
|------------------|---------------------|------------------|-------------|------|------------------------|-----------|------|------|-----------------|-------------------------|---------------------------|
| | | | On | Off | | Pre | Post | Avg. | | | |
| 1115RT-03 | Outside Main Office | Backgrounds | 0726 | 1136 | 250 | 7 | 7 | 7 | 1750 | 16/100 | 0.004 |
| 1115RT-04 | Stage | ↓ | 0728 | 1134 | 246 | 7 | 7 | 7 | 1722 | 14.5/100 | 0.004 |
| 1115RT-01 | Field Blank | - | - | - | - | - | - | - | - | 0/100 | 0.002 |
| 1115RT-02 | Sealed Blank | - | - | - | - | - | - | - | - | 0/100 | 0.002 |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |

Samples Collected By:  Date: 11-15-19 Time: 1136

Samples Analyzed By:  Date: 11-15-19 Time: 1200

Analyst AAR Number: 9537

Lab Drop-Off Lab Name: _____ Turnaround Time: _____

Samples Relinquished By: _____ Date/Time: _____ Samples Received By: _____ Date/Time: _____

Special Instructions: _____

Results Reviewed By: _____