

PHASE CONTRAST MICROSCOPY AREA AIR SAMPLING DATA SHEET

Tighe & Bond

Project Number: 28-2087-033C Date: 9-28-19
 Project Name: Stillmeadow School
 Contractor: MAIS License Number:
 Project Monitor: Bob Hobbin's Project Monitor License Number: 617
 Scope of Work: Floor Classroom 40 - 145 SF of Floor tiled with tile

Sample ID Number	Sample Location	Project Activity	Sample Time		Sample Duration (Min.)	Flow Rate			Volume (Liters)	Fiber Count (Fib/Field)	Concentration (Fibers/CC)
			On	Off		Pre	Post	Avg.			
92884-01	Blank	REN./FAC	/	/	/	/	/	/	0/100	0.0	
-02	Blank	/	/	/	/	/	/	/	0/100	0.0	
-03	o/s Decan - Corridor	/	645	800	75	15.0	15.0	15.0	6/100	<0.0021	
-04	IC	/	805	929	84	15.0	15.0	15.0	4/100	<0.0021	
-05	/	/	806	930	84	15.0	15.0	15.0	2/100	<0.0021	
-06	/	/	807	931	84	15.0	15.0	15.0	4/100	<0.0021	
-07	/	/	808	932	84	15.0	15.0	15.0	2/100	<0.0021	
-08	/	/	809	933	84	15.0	15.0	15.0	2/100	<0.0021	
dup. -08									2/100	<0.0021	

FAC = Final Air Clearance, IC = Inside Containment

Samples Collected By: Bob Hobbin's Date: 9-28-19 Time:
 Samples Analyzed By: BA Date: 9-28-19 Time:

Analyst AAR Number: 902B
 Lab Drop-Off Lab Name:
 Samples Relinquished By: BA Date/Time:
 Results-Reviewed By: BA Date/Time:
 Turnaround Time: BA Date/Time:
 Special Instructions: BA Date/Time: