



EMSL Analytical, Inc.

307 West 38th Street New York, NY 10018

Tel/Fax: (212) 290-0051 / (212) 290-0058

<http://www.EMSL.com> / manhattanlab@emsl.com

EMSL Order: 032003206

Customer ID: TIGH62

Customer PO:

Project ID:

Attention: Eric Foley
Tighe & Bond
213 Court Street
Suite 1100
Middletown, CT 06457

Phone: (860) 704-4760

Fax: (860) 704-4775

Received Date: 02/14/2020 19:35 PM

Analysis Date: 02/14/2020

Collected Date: 02/14/2020

Project: 28-2087-033J / STAMFORD MOLD TASK FORCE / AAIS / REMOVAL OF - 350 SF DRYWALL / JOINT COMPOUND FROM RM 41A

Test Report: Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Appendix A to Subpart E

Sample	Location	Volume (Liters)	Area Analyzed (mm ²)	Non Asb	Asbestos Type(s)	#Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration	
						≥0.5μ < 5μ	≥5μ		(S/mm ²)	(S/cc)
2-14-EJF-13 032003206-0001	INSIDE CONTAINMENT	1282.50	0.0640	0	None Detected	0	0	0.0047	<16.00	<0.0047
2-14-EJF-14 032003206-0002	INSIDE CONTAINMENT	1282.50	0.0640	0	None Detected	0	0	0.0047	<16.00	<0.0047
2-14-EJF-15 032003206-0003	INSIDE CONTAINMENT	1282.50	0.0640	0	None Detected	0	0	0.0047	<16.00	<0.0047
2-14-EJF-16 032003206-0004	INSIDE CONTAINMENT	1282.50	0.0640	0	None Detected	0	0	0.0047	<16.00	<0.0047
2-14-EJF-17 032003206-0005	INSIDE CONTAINMENT	1282.50	0.0640	0	None Detected	0	0	0.0047	<16.00	<0.0047

Analyst(s)

Isaac Mendez (5)

James Hall, Laboratory Manager
or other approved signatory

EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. This report must not be used to claim product certification, approval, or endorsement by NVLAP, NIST, or any agency of the federal government. Results reported in both structures/cm³ and structures/mm² are dependent on the volume of air sampled and measured by non-laboratory personnel are not the responsibility of EMSL and are not covered by the laboratory's NVLAP accreditation. Samples received in good condition unless otherwise noted. Estimated accuracy, precision and uncertainty data available upon request.

Samples analyzed by EMSL Analytical, Inc. New York, NY NVLAP Lab Code 101048-9, AIHA-LAP, LLC--IHLAP Accredited #102581, NYS ELAP 11506, NJ NY022, CT PH-0170, MA AA000170

Initial report from: 02/14/2020 23:46 PM

032003206

Tighe & Bond

TRANSMISSION ELECTRON MICROSCOPY AREA AIR SAMPLING DATA SHEET

Project Number: 28-2087-0332 Date: 2.14.2020
 Project Name: Stamford Mold Task Force
 Contractor: AAIS
 Project Monitor: Erik Foley License Number:
 Project Monitor License Number: 0759
 Scope of Work: Removal of ~ 350 sf drywall / joint compound from Rm 41A

Sample ID Number	Sample Location	I/O	Sample Time		Sample Duration (Min.)	Flow Rate			Total Volume (Liters)
			On	Off		Pre	Post	Avg.	
2.14-ESF-13	Inside Containment	1	1359	1614	135	9.5	9.5	9.5	1282.5
14	↓	1	1400	1615	135	9.5	9.5	9.5	1282.5
15		1	1400	1615	135	9.5	9.5	9.5	1282.5
16		1	1400	1615	135	9.5	9.5	9.5	1282.5
17		1	1401	1616	135	9.5	9.5	9.5	1282.5
18		Outside Containment	0	1140	1355	135	9.5	9.5	9.5
19	↓	0	1140	1355	135	9.5	9.5	9.5	1282.5
20		0	1140	1355	135	9.5	9.5	9.5	1282.5
21		0	1141	1356	135	9.5	9.5	9.5	1282.5
22		0	1141	1356	135	9.5	9.5	9.5	1282.5
23		Field Blank (In)	1						
24	Field Blank (Out)	0							
25	Sealed Control Blank	--							

Samples Collected By: Erik Foley Date: 2.14.2020 Time: 1356, 1616
 Samples Rec'd/Sent By: [Signature] Date: 2/14/20 / 2.14.2020 Time: 7:35 PM
 Shipped to: EMSL (State) Lab Drop Off EMSL, NYC
 Shipment Method: FedEx UPS Overnight UPS Ground Other
 Analysis Method: TEM AHERA Turnaround Time: 6 hrs Special Instructions: Call 803.584.0734 with results
 Email to: E.Foley@tighebond.com, M.Febbraio@tighebond.com
SM verbal@1148pm ct
 213 Court Street • Middletown, CT 06457 • Tel 860.704.4760 • Fax 860.704.4775
SM 2-14-20 2:30