

From: [Gami, Bharat](#)
To: [Tim Yahn](#)
Subject: Status of B-22-322 for reconstruction of collapsed slab at Allure
Date: Wednesday, March 30, 2022 11:44:23 AM

Hi Tim:

The permit for demolition of collapsed slab (B-22-169) asked BLT/HRSE to clarify how they would ensure the City that there are no other areas that are either incorrectly constructed or missing required elements before the issuance of next phase of permit to reconstruct the collapsed slab. They were also asked to clarify the proposed path forward for testing and analyzing existing upper slab that remains in place adjacent to the collapse area but not constructed in accordance with the approved shop drawings.

It is WJE's opinion that Nondestructive testing (NDT) needs to be done prior to issuance of permit. NDT may indicate an issue that the reconstruction/repair detail does not address. Area limits of NDT/GPR have not been finalized yet. A permit will be issued once WJE is satisfied with the extent of reconstruction shown in plans based on review of NDT/GPR test results and their ongoing investigation. Thank you very much.

With best regards

Bharat Gami
Chief Building Official

City of Stamford
[Building Department](#)
888 Washington Boulevard, 7th Floor
Stamford CT 06901