


Legend	
	THERMOGRAM
<u>NIC</u>	NOT IN CONTRACT
	SUSPECTED WET INSULATION
	DRAIN

Areas: Total of All Roofs		
(in approximate square feet)		
Square Footage of Roof Inspected:	17,403	
Square Footage of Suspected Wet Area:	61	
Percentage of Suspected Wet Area:	<1%	



INFRA-RED ROOF MOISTURE ANALYSIS



IR ANALYZERS
Vector Mapping
 INFRARED • ELD FUSION • NUCLEAR
 P: (800) 879-3964 • F: 866-506-3522 • email: info@iranalyzers.com
 NATIONWIDE SERVICE

VIKING CONSTRUCTION
 BRIDGEPORT, CT
 TOQUAM ELEMENTARY
 STAMFORD, CT

SCALE:	3/32"=1'-0"
DATE:	05-22 & 24-19
PAGE:	1 OF 1
DRAWN BY:	DMR
JOB#:	19231X12