



# EMSL Analytical, Inc.

29 North Plains Highway, Unit # 4 Wallingford, CT 06492

Tel/Fax: (203) 284-5948 / (203) 284-5978

<http://www.EMSL.com> / [wallingfordlab@emsl.com](mailto:wallingfordlab@emsl.com)

EMSL Order: 241903509
Customer ID: TIGH62
Customer PO:
Project ID:

<b>Attention:</b> Randy Taylor Tighe & Bond 213 Court Street Suite 1100 Middletown, CT 06457  <b>Project:</b> 28-2087-033/STAMFORD MOLD TASK FORCE-TOQUAM E.S.	<b>Phone:</b> (860) 704-4760 <b>Fax:</b> (860) 704-4775 <b>Received Date:</b> 07/05/2019 15:55 PM <b>Analysis Date:</b> 07/05/2019 <b>Collected Date:</b> 07/05/2019
--	--

## Test Report: Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Appendix A to Subpart E

Sample	Location	Volume (Liters)	Area Analyzed (mm <sup>2</sup> )	Non Asb	Asbestos Type(s)	#Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration	
						≥0.5μ < 5μ	≥5μ		(S/mm <sup>2</sup> )	(S/cc)
070519RT-01C	CORRIDOR-SECTION 3-COPIER ROOM	1269.00	0.0650	0	None Detected	0	0	0.0047	<15.00	<0.0047
241903509-0001										
070519RT-02C	CORRIDOR-SECTION 3-ROOM 8	1269.00	0.0650	0	None Detected	0	0	0.0047	<15.00	<0.0047
241903509-0002										
070519RT-03C	CORRIDOR-SECTION 3-ROOM 3	1269.00	0.0650	0	None Detected	0	0	0.0047	<15.00	<0.0047
241903509-0003										
070519RT-04C	CORRIDOR-SECTION 3-ROOM 1	1269.00	0.0650	0	None Detected	0	0	0.0047	<15.00	<0.0047
241903509-0004										
070519RT-05C	CORRIDOR-SECTION 3-ROOM 2A	1269.00	0.0650	0	None Detected	0	0	0.0047	<15.00	<0.0047
241903509-0005										

Analyst(s)

Leslie Tetrick (5)

Almedina Hodzic, Asbestos Laboratory Manager  
or other approved signatory

EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. This report must not be used to claim product certification, approval, or endorsement by NVLAP, NIST, or any agency of the federal government. Results reported in both structures/cm3 and structures/mm2 are dependent on the volume of air sampled and measured by non-laboratory personnel are not the responsibility of EMSL and are not covered by the laboratory's NVLAP accreditation. Samples received in good condition unless otherwise noted. Estimated accuracy, precision and uncertainty data available upon request.

Samples analyzed by EMSL Analytical, Inc. Wallingford, CT NVLAP Lab Code 200700-0, NYS ELAP 12063, CT PH-0322, MA AA000191, RI AAL-108T3, VT AL357101

Initial report from: 07/05/2019 17:41 PM

241903509

## TRANSMISSION ELECTRON MICROSCOPY AREA AIR SAMPLING DATA SHEET

Tighe &amp; Bond

Project Number: 28-2087-033	Date: 7/5/19
Project Name: Stamford - Mold Task Force - Taquam E.S.	
Contractor: AAIS	License Number: 017
Project Monitor: Randy Taylor	Project Monitor License Number: 743
Scope of Work: Drywall + Taping / Joint Compound	

Sample ID Number	Sample Location	I/O	Sample Time		Sample Duration (Min.)	Flow Rate			Total Volume (Liters)
			On	Off		Pre	Post	Avg.	
070519RT-01C	Corridor - Section 3 - Copiers Room	I	0648	0907	135	9.4	9.4	9.4	1,269
-02C	-Room 8	I	0649	0908	135	9.4	9.4	9.4	1,269
-03C	-Room 3	I	0650	0909	135	9.4	9.4	9.4	1,269
-04C	-Room 1	I	0651	0910	135	9.4	9.4	9.4	1,269
-05C	Room 2A	I	0652	0911	135	9.4	9.4	9.4	1,269
-06C	OCB - Decon	O	0654	0913	135	9.4	9.4	9.4	1,269
-07C		O	0655	0914	135	9.4	9.4	9.4	1,269
-08C		O	0656	0915	135	9.4	9.4	9.4	1,269
-09C		O	0657	0916	135	9.4	9.4	9.4	1,269
-10C		O	0658	0917	135	9.4	9.4	9.4	1,269
-11C	Field Blank (In)	I							
-12C	Field Blank (Out)	O							
-13C	Sealed Control Blank	---							

Samples Collected By: Randy Taylor	Date: 7/5/19	Time: 0648 - 0917
Samples Rec'd/Sent By: Randy Taylor	Date: 7/5/19	Time: /
Shipped to: <input type="checkbox"/> EMSL (State)	<input checked="" type="checkbox"/> Lab Drop Off	
Shipment Method: <input type="checkbox"/> FedEx	<input type="checkbox"/> UPS Overnight	<input type="checkbox"/> UPS Ground
<input type="checkbox"/> Other		
Analysis Method: TEM AHERA	Turnaround Time: 6 Hours	Special Instructions:
Email to: MFebraro@Tighebond.com		

213 Court Street • Middletown, CT 06457 • Tel 860.704.4760 • Fax 860.704.4775

