

EMSL Analytical, Inc.

29 North Plains Highway, Unit #4 Wallingford, CT 06492

Phone/Fax: (203) 284-5948 / (203) 284-5978 http://www.EMSL.com / wallingfordlab@emsl.com Order ID: 241902279 Customer ID: TIGH62

Customer PO:

Project ID: Stamford Mold Task

(860) 704-4760 Kevin McCarthy Phone: Attn: (860) 704-4775 Tighe & Bond Fax: Collected: 05/01/2019 213 Court Street Suite 1100 Received: 05/03/2019 Analyzed: 05/07/2019 Middletown, CT 06457

Proj: 28-2087-033M/ STAMFORD MOLD TASK FORCE, RIPPOWAM MIDDLE SCHOOL (Stamford Mold Task Force)

Test Report: Microscopic Examination of Fungal Spores, Fungal Structures, Hyphae, and Other Particulates from Swab Samples (EMSL Method MICRO-SOP-200)

Lab Sample Number: Client Sample ID: Sample Location:	241902279-0001 SW-01 EAST CAFÉ WALL-GYPSUM BOARD	241902279-0002 SW-02 WALL CORNER BY AUDITORIUM	241902279-0003 SW-03 GIRL'S LOCKER ROOM-METAL DIFFUSER		
Spore Types	Category	Category	Category	-	-
Alternaria (Ulocladium)	-	-	-	-	-
Ascospores	-	-	Rare	-	-
Aspergillus/Penicillium	-	-	-	-	-
Basidiospores	Rare	-	Rare	-	-
Bipolaris++	-	-	-	-	-
Chaetomium	-	-	-	-	-
Cladosporium	-	-	-	-	-
Curvularia	-	-	-	-	-
Epicoccum	-	-	-	-	-
Fusarium	-	-	-	-	-
Ganoderma	-	-	-	-	-
Myxomycetes++	-	-	Low	-	-
Pithomyces++	Rare	-	Low	-	-
Rust	-	-	-	-	-
Scopulariopsis/Microascus	-	-	-	-	-
Stachybotrys/Memnoniella	-	*Medium*	-	-	-
Unidentifiable Spores	-	-	-	-	-
Zygomycetes	-	-	-	-	-
Nigrospora	Rare	-	-	-	-
Hyphal Fragment	High	Low	Rare	-	-
Insect Fragment	-	-	-	-	-
Pollen	-	-	Low	-	-
Fibrous Particulate	Rare	Low	Low	-	-

Category: Count/per area analyzed - Rare: 1 to 10 Low: 11 to 100 Medium: 101 to 1000 High: >1000

Denotes Not Detected.

++ = Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

* = Sample contains fruiting structures and/or hyphae associated with the spores.

No discernable field blank was submitted with this group of samples.

Gloria V. Oriol, Microbiology Manager or Other Approved Signatory

Samples received in good condition unless otherwise noted. EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. When the information supplied by the customer can affect the validity of the results, it will be noted on the report. Interpretation of the data contained in this report is the responsibility of the client. The report reflects the samples as received. When the

Initial report from: 05/08/2019 10:24:53

OrderID: 241902279



24/902279

213 Court Street, Suite 1100, Middletown, CT 06457

Phone 860-704-4760

SAMPLE LOG FOR MICROBIAL ANALYSIS

Sheet 1 of 1

Project Name: Stamford Mold Task Force			Project No. <u>28-2087-033M</u>		
Building:R	Rippowam Middle So	Project Manager: <u>McCarthy</u>			
Sample ID	Sample Type	Sample Location	Material		
SW-01	Swab	East Café Wall	Gypsum Board		
SW-02	Swab	Wall corner by Auditorium courtya	rd Gypsum Board		
SW-03	Swab	Girls' Locker Room	Metal Diffuser		
			,		
Analysis Method:	☑ M041 ☐ Other		Turnaround Time _72 hour		
Based on the turna	round time indicated ab Please call the office if a	ove, analyses are due to Tighe & Bond, Inc. on alyses will be late at 860-704-4760.	on or before this date:		
Email Results to:	Knocarthy @tight		Report Total # of Samples: 3		
Special Instruction	OII	Analysis - Fungal Direct Identification. Note			
Samples collecte		Offulle Date: 5119			
	[Sent by] [
	d by:		Time:		
12.	EMSL State ent: ☑ Fed Ex ☐ O		MAY 0 3 2019		
			By		