

# PHASE CONTRAST MICROSCOPY AREA AIR SAMPLING DATA SHEET

**Tighe & Bond**

Project Number: 28-2087-033N Date: 9-27-19

Project Name: Turn of River Middle School

Contractor: HAAS License Number: \_\_\_\_\_

Project Monitor: Bob Hobbins Project Monitor License Number: 617

Scope of Work: Floor Tack Board

Sample ID Number	Sample Location	Project Activity	Sample Time		Sample Duration (Min.)	Flow Rate			Volume (Liters)	Fiber Count (Fib/Field)	Concentration (Fibers/CC)
			On	Off		Pre	Post	Avg.			
927BH-01	Blank	Prep/Rem									
-02	Blank										
-03	Corridor w/ s Am 107	↓	1515	1700	225	6.9	6.9	1,380	9/100	0.0	
-04	Inside Work Area	FAC	1915	2047	92	15.0	15.0	1,380	3/100	0.0020	
-05	↓	↓	1916	2048	92	15.0	15.0	1,380	2/100	0.0020	
-06			1917	2049	92	15.0	15.0	1,380	2/100	0.0020	
-07			1918	2050	92	15.0	15.0	1,380	1/100	0.0020	
-08			1919	2051	92	15.0	15.0	1,380	2/100	0.0020	
dur. -08											

FAC = Final Air Clearance

Samples Collected By: B. Hobbins Date: 9-27-19 Time: \_\_\_\_\_

Samples Analyzed By: BH Date: 9-27-19 Time: \_\_\_\_\_

Analyst AAR Number: 9028

Lab Drop-Off Lab Name: \_\_\_\_\_ Turnaround Time: \_\_\_\_\_

Samples Relinquished By: \_\_\_\_\_ Date/Time: \_\_\_\_\_ Special Instructions: \_\_\_\_\_

Results-Reviewed By: \_\_\_\_\_ Samples Received By: \_\_\_\_\_ Date/Time: \_\_\_\_\_