




Legend	
	THERMOGRAM
	SUSPECTED WET INSULATION
<u>NIC</u>	NOT IN CONTRACT

Areas: Total of All Roofs		
<small>(in approximate square feet)</small>		
Square Footage of Roof Inspected:		37,705
Square Footage of Suspected Wet Area:		151
Percentage of Suspected Wet Area:		<1%



**INFRA-RED ROOF MOISTURE ANALYSIS**



**IR ANALYZERS**  
**Vectr Mapping**  
 INFRARED • ELD FUSION • NUCLEAR

F: (800) 879-3964 • F: 866-506-3522 • email: info@iranalyzers.com  
 NATIONWIDE SERVICE

VIKING CONSTRUCTION  
 BRIDGEPORT, CT  
 ACADEMY OF INFORMATION TECH. & ENG.  
 STAMFORD, CT

SCALE:	1/16"=1'-0"
DATE:	05-15-19
PAGE:	1 OF 1
DRAWN BY:	DMR
JOB#:	19231X20