



EMSL Analytical, Inc.

307 West 38th Street New York, NY 10018

Tel/Fax: (212) 290-0051 / (212) 290-0058

<http://www.EMSL.com> / manhattanlab@emsl.com

EMSL Order: 031924514

Customer ID: TIGH62

Customer PO:

Project ID:

Attention: M. Febbraio
Tighe & Bond
213 Court Street
Suite 1100
Middletown, CT 06457

Phone: (860) 704-4760

Fax: (860) 704-4775

Received Date: 09/30/2019 18:02 PM

Analysis Date: 09/30/2019

Collected Date: 09/30/2019

Project: 28-2087-033 / STAMFORD - MOLD TASK FORCE - WHHS /

Test Report: Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Appendix A to Subpart E

Sample	Location	Volume (Liters)	Area Analyzed (mm ²)	Non Asb	Asbestos Type(s)	#Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration	
						≥0.5μ < 5μ	≥5μ		(S/mm ²)	(S/cc)
093019RT - 01C 031924514-0001	CORRIDOR - FAR RIGHT	1306.60	0.0640	0	None Detected	0	0	0.0046	<16.00	<0.0046
093019RT - 02C 031924514-0002	CORRIDOR - RIGHT	1306.60	0.0640	0	None Detected	0	0	0.0046	<16.00	<0.0046
093019RT - 03C 031924514-0003	CORRIDOR - CENTER	1306.60	0.0640	0	None Detected	0	0	0.0046	<16.00	<0.0046
093019RT - 04C 031924514-0004	CORRIDOR - LEFT	1306.60	0.0640	0	None Detected	0	0	0.0046	<16.00	<0.0046
093019RT - 05C 031924514-0005	CORRIDOR - FAR LEFT	1306.60	0.0640	0	None Detected	0	0	0.0046	<16.00	<0.0046

Analyst(s)

Isaac Mendez (5)

James Hall, Laboratory Manager
or other approved signatory

EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. This report must not be used to claim product certification, approval, or endorsement by NVLAP, NIST, or any agency of the federal government. Results reported in both structures/cm³ and structures/mm² are dependent on the volume of air sampled and measured by non-laboratory personnel are not the responsibility of EMSL and are not covered by the laboratory's NVLAP accreditation. Samples received in good condition unless otherwise noted. Estimated accuracy, precision and uncertainty data available upon request.

Samples analyzed by EMSL Analytical, Inc. New York, NY NVLAP Lab Code 101048-9, AIHA-LAP, LLC--IHLAP Accredited #102581, NYS ELAP 11506, NJ NY022, CT PH-0170, MA AA000170

Initial report from: 09/30/2019 22:45 PM

031924514

TRANSMISSION ELECTRON MICROSCOPY AREA AIR SAMPLING DATA SHEET

Tighe&Bond

Project Number: 28-2087-033 Date: 9/30/19
 Project Name: Stamford - Mold Task force - W#HS
 Contractor: AAIS License Number: 017
 Project Monitor: Randy Taylor Project Monitor License Number: 743
 Scope of Work: ~600 SF of Drywall & Taping Compound

Sample ID Number	Sample Location	I/O	Sample Time		Sample Duration (Min.)	Flow Rate			Total Volume (Liters)
			On	Off		Pre	Post	Avg.	
0930ART-01C	Corridor - Far Right	1	1320	1539	139	9.4	9.4	9.4	1306.6
-02C	- Right	1	1321	1540	139	9.4	9.4	9.4	1306.6
-03C	- Center	1	1322	1541	139	9.4	9.4	9.4	1306.6
-04C	- Left	1	1323	1542	139	9.4	9.4	9.4	1306.6
-05C	- Far Left	1	1324	1543	139	9.4	9.4	9.4	1306.6
-06C	OCB - Decon	0	1326	1545	139	9.4	9.4	9.4	1306.6
-07C		0	1327	1546	139	9.4	9.4	9.4	1306.6
-08C		0	1328	1547	139	9.4	9.4	9.4	1306.6
-09C		0	1329	1548	139	9.4	9.4	9.4	1306.6
-10C		0	1330	1549	139	9.4	9.4	9.4	1306.6
-11C	Inside Blank	1							
-12C	Outside Blank	0							
-13C	Sealed Blank								

2019 SEP 30 PH 6:02
 MANHATTAN LAB RECEIVED

Samples Collected By: Randy Taylor Date: 9/30/19 Time: /
 Samples Rec'd/Sent By: Randy Taylor Date: 9/30/19 Time: /
 Shipped to: EMSL (State) Lab Drop Off NYC

Shipment Method: FedEx UPS Overnight UPS Ground Other Tech
 Analysis Method: TEM AHERA Turnaround Time: 6 hour Special Instructions:
 Email to: mfebbraio@tighebond.com
 Rec @ Doc 9/30/19
 S.M.S. 9-30-19 20:15

213 Court Street • Middletown, CT 06457 • Tel 860.704.4760 • Fax 860.704.4775