



EMSL Analytical, Inc.

29 North Plains Highway, Unit # 4 Wallingford, CT 06492

Tel/Fax: (203) 284-5948 / (203) 284-5978

<http://www.EMSL.com> / wallingfordlab@emsl.com

EMSL Order: 241906238
Customer ID: TIGH62
Customer PO:
Project ID:

Attention: Meredith Febbraio Tighe & Bond 213 Court Street Suite 1100 Middletown, CT 06457 Project: 28-2087-033/ STAMFORD MOLD TASK FORCE, WESTHILL H.S.	Phone: (860) 704-4760 Fax: (860) 704-4775 Received Date: 10/24/2019 11:05 AM Analysis Date: 10/24/2019 Collected Date: 10/24/2019
---	--

Test Report: Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Appendix A to Subpart E

Sample	Location	Volume (Liters)	Area Analyzed (mm ²)	Non Asb	Asbestos Type(s)	#Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration	
						≥0.5μ < 5μ	≥5μ		(S/mm ²)	(S/cc)
102419RT-01C 241906238-0001	CENTER-SCAFFOLDING	1278.40	0.0690	0	None Detected	0	0	0.0044	<14.00	<0.0044
102419RT-02C 241906238-0002	NORTH-SCAFFOLDING	1278.40	0.0690	0	None Detected	0	0	0.0044	<14.00	<0.0044
102419RT-03C 241906238-0003	EAST-FLOOR	1278.40	0.0690	0	None Detected	0	0	0.0044	<14.00	<0.0044
102419RT-04C 241906238-0004	SOUTH-FLOOR	1278.40	0.0690	0	None Detected	0	0	0.0044	<14.00	<0.0044
102419RT-05C 241906238-0005	WEST-FLOOR	1278.40	0.0690	0	None Detected	0	0	0.0044	<14.00	<0.0044

Analyst(s)

Almedina Hodzic (5)

Almedina Hodzic, Asbestos Laboratory Manager
or other approved signatory

EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. This report must not be used to claim product certification, approval, or endorsement by NVLAP, NIST, or any agency of the federal government. Results reported in both structures/cm³ and structures/mm² are dependent on the volume of air sampled and measured by non-laboratory personnel are not the responsibility of EMSL and are not covered by the laboratory's NVLAP accreditation. Samples received in good condition unless otherwise noted. Estimated accuracy, precision and uncertainty data available upon request.

Samples analyzed by EMSL Analytical, Inc. Wallingford, CT NVLAP Lab Code 200700-0, NYS ELAP 12063, CT PH-0322, MA AA000191, RI AAL-108T3, VT AL357101

Initial report from: 10/24/2019 15:41 PM

TRANSMISSION ELECTRON MICROSCOPY AREA AIR SAMPLING DATA SHEET

Tight&Bond

241906238

Project Number: 28-2087-033 Date: 10/24/19
 Project Name: Stamford - Mold Task Force - Westhill H.S.
 Contractor: AAIS License Number: 017
 Project Monitor: Randy Taylor Project Monitor License Number: 743
 Scope of Work: Pool Containment - Ceiling Tiles (ACH < 1%)

Sample ID Number	Sample Location	I/O	Sample Time		Sample Duration (Min.)	Flow Rate			Total Volume (Liters)
			On	Off		Pre	Post	Avg.	
102419RT-01C	Center - Scaffolding	1	0606	0822	136	9.4	9.4	9.4	1278.4
-02C	North - Scaffolding	1	0607	0823	136	9.4	9.4	9.4	1278.4
-03C	East - Floor	1	0608	0824	136	9.4	9.4	9.4	1278.4
-04C	South - Floor	1	0609	0825	136	9.4	9.4	9.4	1278.4
-05C	West - Floor	1	0610	0826	136	9.4	9.4	9.4	1278.4
-06C	OCB - Recan	0	0612	0828	136	9.4	9.4	9.4	1278.4
-07C	↓	0	0613	0829	136	9.4	9.4	9.4	1278.4
-08C		0	0614	0830	136	9.4	9.4	9.4	1278.4
-09C		0	0615	0831	136	9.4	9.4	9.4	1278.4
-10C	↓	0	0616	0832	136	9.4	9.4	9.4	1278.4
-11C	Inside Blank	1	---	---	---	---	---	---	---
-12C	Outside Blank	0	---	---	---	---	---	---	---
-13C	Sealed Blank	---	---	---	---	---	---	---	---

Samples Collected By: Randy Taylor Date: 10/24/19 Time: 0606 - 0832
 Samples Rec'd/Sent By: Randy Taylor Date: 10/24/19 Time: 0606 - 0832

Shipped to: EMSL (State) Lab Drop Off Wallingford
 Shipment Method: Fedex UPS Overnight UPS Ground Other Tech
 Analysis Method: TEM AHERA Turnaround Time: 6 Hour Special Instructions:
 Email to: m.felbma@tighthead.com

213 Court Street • Middletown, CT 06457 • Tel 860.704.4760 • Fax 860.704.4775

