



EMSL Analytical, Inc.

29 North Plains Highway, Unit # 4 Wallingford, CT 06492

Tel/Fax: (203) 284-5948 / (203) 284-5978

<http://www.EMSL.com> / wallingfordlab@emsl.com

| |
|-----------------------|
| EMSL Order: 241903543 |
| Customer ID: TIGH62 |
| Customer PO: |
| Project ID: |

| | |
|--|--|
| Attention: Eric Foley Tighe & Bond 213 Court Street Suite 1100 Middletown, CT 06457 Project: 28-2087-033P/ DAVENPORT CLASSROOM RENOVATION | Phone: (860) 704-4760 Fax: (860) 704-4775 Received Date: 07/08/2019 14:55 PM Analysis Date: 07/09/2019 Collected Date: 07/08/2019 |
|--|--|

Test Report: Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Appendix A to Subpart E

| Sample | Location | Volume (Liters) | Area Analyzed (mm ²) | Non Asb | Asbestos Type(s) | #Structures | | Analytical Sensitivity (S/cc) | Asbestos Concentration | |
|------------------------------|--------------------|-----------------|----------------------------------|---------|------------------|-------------|-----|-------------------------------|------------------------|---------|
| | | | | | | ≥0.5μ < 5μ | ≥5μ | | (S/mm ²) | (S/cc) |
| 7-8-EJF-12 241903543-0001 | INSIDE CONTAINMENT | 1251.25 | 0.0650 | 0 | None Detected | 0 | 0 | 0.0047 | <15.00 | <0.0047 |
| 7-8-EJF-13 241903543-0002 | INSIDE CONTAINMENT | 1235.00 | 0.0650 | 0 | None Detected | 0 | 0 | 0.0048 | <15.00 | <0.0048 |
| 7-8-EJF-14 241903543-0003 | INSIDE CONTAINMENT | 1235.00 | 0.0650 | 0 | None Detected | 0 | 0 | 0.0048 | <15.00 | <0.0048 |
| 7-8-EJF-15 241903543-0004 | INSIDE CONTAINMENT | 1235.00 | 0.0650 | 0 | None Detected | 0 | 0 | 0.0048 | <15.00 | <0.0048 |
| 7-8-EJF-16 241903543-0005 | INSIDE CONTAINMENT | 1235.00 | 0.0650 | 0 | None Detected | 0 | 0 | 0.0048 | <15.00 | <0.0048 |

Analyst(s)

Leslie Tetrick (5)

Almedina Hodzic, Asbestos Laboratory Manager
or other approved signatory

EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. This report must not be used to claim product certification, approval, or endorsement by NVLAP, NIST, or any agency of the federal government. Results reported in both structures/cm³ and structures/mm² are dependent on the volume of air sampled and measured by non-laboratory personnel are not the responsibility of EMSL and are not covered by the laboratory's NVLAP accreditation. Samples received in good condition unless otherwise noted. Estimated accuracy, precision and uncertainty data available upon request.

Samples analyzed by EMSL Analytical, Inc. Wallingford, CT NVLAP Lab Code 200700-0, NYS ELAP 12063, CT PH-0322, MA AA000191, RI AAL-108T3, VT AL357101

Initial report from: 07/09/2019 11:03 AM

241903543

TRANSMISSION ELECTRON MICROSCOPY AREA AIR SAMPLING DATA SHEET

Tighe&Bond

Project Number: 28-2087-033P

Date: 7-8-19

Project Name: Davenport Classroom Renovation


Contractor: AAIS

License Number:

Project Monitor: Erik Foley

Project Monitor License Number: 0754

Scope of Work: Removal of sheetrock/joint compound / tackboard adhesive, sinks, transite



| Sample ID Number | Sample Location | I/O | Sample Time | | Sample Duration (Min.) | Flow Rate | | | Total Volume (Liters) | |
|------------------|----------------------|--------------------------------|-------------|------|------------------------|-----------|------|-------|-----------------------|--------|
| | | | On | Off | | Pre | Post | Avg | | |
| 78-EJF-12 | Inside Containment | | 1125 | 1335 | 130 | 9.5 | 9.75 | 9.625 | 1251.25 | |
| 13 | ↓ | | 1126 | 1336 | 130 | 9.5 | 9.5 | 9.5 | 1235 | |
| 14 | | | 1126 | 1336 | 130 | 9.5 | 9.5 | 9.5 | 1235 | |
| 15 | | | 1126 | 1336 | 130 | 9.5 | 9.5 | 9.5 | 1235 | |
| 16 | | | 1127 | 1337 | 130 | 9.5 | 9.5 | 9.5 | 1235 | |
| 17 | | Outside Containment - At Decon | 0 | 0905 | 1115 | 130 | 9.5 | 9.5 | 9.5 | 1235 |
| 18 | | ↓ | 0 | 0906 | 1116 | 130 | 9.5 | 9 | 9.25 | 1202.5 |
| 19 | 0 | | 0906 | 1116 | 130 | 9.5 | 10 | 9.75 | 1267.5 | |
| 20 | 0 | | 0906 | 1116 | 130 | 9.5 | 9.5 | 9.5 | 1235 | |
| 21 | 0 | | 0906 | 1114 | 130 | 9.5 | 9 | 9.25 | 1202.5 | |
| 22 | Field Blank (In) | | | | | | | | | |
| 23 | Field Blank (Out) | | 0 | | | | | | | |
| 24 | Sealed Control Blank | --- | | | | | | | | |

Samples Collected By:

Date: 7-8-19

Time: 1116 / 1337

Samples Rec'd/Sent By: / Samuel Ennis

Date: 7/8/19 /

Time: 2:50pm /

Shipped to: EMSL (State) Lab Drop OffShipment Method: FedEx UPS Overnight UPS Ground Other dropoff

Analysis Method: TEM AHERA Turnaround Time: 6 hour

Special Instructions: Call 203-584-0734 with results ASAP

Email to M.Febbraio@tighebond.com

E.Foley@tighebond.com

213 Court Street • Middletown, CT 06457 • Tel 860.704.4760 • Fax 860.704.4775