

PHASE CONTRAST MICROSCOPY AREA AIR SAMPLING DATA SHEET

Tighe&Bond

Project Name: Stamford - Mold Task Force
 Project Location: Davenport Bridge
 Work Area Designation: Rm 28 + Rm 29
 Microscope #: 23

Project Number: 28-2087-033

Sampling Date: 3/28/19

Project Monitor Name: Randy Taylor

Project Monitor License #: 743

Sample #	Sample Location	Project Activity	Sample Time (minutes)			Flow Rate (Liters/Minute)		Average Flow Rate (Liters/Min)	Total Volume (Liters)	Fiber Count (Fib/Field)	Concentration (Fibers/CC)
			On	Off	Min	Pre	Post				
032819RT-0		Background	1833	2000		14.9	14.9	14.9		5/100	40.002
-02			1834	2001		14.9	14.9	14.9		4/100	40.002
-03			1835	2002		14.9	14.9	14.9		5/100	40.002
-04	Field Blank		-	-	-	-	-	-	-	0/100	40.002
-05	Seal Blank		-	-	-	-	-	-	-	0/100	40.002
-02	Rep Count		-	-	-	-	-	-	-	3/100	40.002

Chain of Custody and Sample Receiving Log

Samples Analyzed By:	<u>Randy Taylor</u>	Date:	<u>3/28/19</u>	Time:		AAR#	<u>9450</u>
Sample Collected By:	<u>Randy Taylor</u>	Date:	<u>3/28/19</u>	Time:			
Samples Relinquished By:		Date:		Time:			
Samples Received By:		Date:		Time:			
Results Reviewed By:		Date:		Time:			

213 Court Street • Middletown, CT 06457 • Tel 860.704.4760 • Fax 860.704.4775