

## Hart

- Classrooms
  - AAIS to determine scope of work and schedule
  - Work includes replacing drywall around windows, pipe insulation and remove wall covering behind cork boards.
  - Long term ventilation upgrade/replacement system required.
    - Future capital project
- Media Center Sheet rocking and Caulking
  - Window caulking to be completed this Friday
- Water Intrusion Issues
  - Similar to Stark, temporary solution this year to lead to a more extensive project next year.
    - Building envelope study currently being performed by Silver Pettrucelli
    - MTF, Silver Pettrucelli and Bismark Construction agreed to extend scope of study to entire 97 addition to determine if conditions seen in kindergarten exterior could possibly extend to rest of addition.
- Pipe Insulation
  - KNK currently working on pipe insulation
- Tucker Mechanical performed an HVAC analysis of the building
  - Report is being completed
- Complete roof drain pipe clearing and repairs to be completed this summer.
- Playgrounds

- Playground Medic performed an assessment of playgrounds throughout the City and crafted reports on issues found. SAMG to assess.
- Infra-red Roof Analyzers
  - [Roof Model](#)
  - [Report](#)
- Roof Repair Report
  - [Gottfried](#)
- [Water Tests](#)
  - Incoming potable water tested within healthy limits.

If you have any additional questions, please email  
**[SAMG@stamfordct.gov](mailto:SAMG@stamfordct.gov)**